

Report of Measurements for Models: MSLB-2-XXXX-1-X-XXXXXX and MSLB-2-XXXX-2-X-XXXXXX For

Bridgelux 101 Portola Ave Livermore, CA 94551 October 31, 2012

Model Number: MSLB-2-XXXX-1-X-XXXXXX and MSLB-2-XXXX-2-X-XXXXXX

Test Engineer:

Chris Rose WiSE Engineer UL - WiSE

Wireless, Interoperability, Security/Payments & EMC

Chris Rose

Reviewer:

Michelle Henderson (919-549-1471) WiSE Operations Manager

UL - WiSE

Wireless, Interoperability, Security/Payments & EMC

This Document was prepared by:

UL LLC 12 Laboratory Dr. Research Triangle Park, NC 27709 (919) 549-1400

Copyright © 2012 UL LLC

All Rights Reserved

UL LLC reports apply only to the specific samples tested under stated test conditions. It is the manufacturer's responsibility to assure that additional production units of this model are manufactured with identical electrical and mechanical components. UL LLC shall have no liability for any deductions, inferences, or generalizations drawn by the client or others from UL LLC issued reports.

This report is the confidential property of the client. As a mutual protection to our clients, the public, and ourselves, extracts from the test report shall not be reproduced except in full without UL' written approval. This report shall not be used, by the client, to claim product endorsement by NVLAP or any agency of the US government.

Issued: October 31, 2012 Revision: 1.0 Client Name: Bridgelux

Pr
Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00 Project Number: 12CA49116

Table of Contents

1.0 EXECUTIVE SUMMARY	3
1.1 Introduction	3
1.2 Revision History	5
1.3 Test Result Summary	5
2.0 ANALYSIS SCOPE	6
2.1 Product Description	6
2.2 MODIFICATIONS NECESSARY FOR COMPLIANCE	6
2.3 EUT OPERABILITY	6
2.4 TESTING FACILITIES	6
3.0 UL TECHNICAL STAFF	7
4.0 ANALYSIS CRITERIA	7
ANNEX 1 – EQUIPMENT PHOTOS	8
ANNEX 2 – EARTHQUAKE	10
ANNEX 3: EQUIPMENT ANCHOR CRITERIA	14
ANNEX 4: MECHANICAL SHOCK	17

Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

1.0 EXECUTIVE SUMMARY

1.1 Introduction

This audit report examines the following for conformance to Telcordia Technologies GR-63-CORE, Issue 4, April 2012 – Section 4.4.1 – Earthquake (Zone 4), Telcordia Technologies GR-63-CORE, Issue 4, April 2012 – Section 4.4.3 – Equipment Anchor Criteria, and ETSI EN 300019-2-3 V2.2.2 (2003-2004) – Shock (Class T3.1)*.

Luminaire Models Evaluated:

- MSLB-2-0606-1-B-AAAA00 (with Thomas Research Products LED96W-034-C2800-M-D)
- MSLB-2-0606-2-B-AAAA00 (Mean Well HVG-100-30BBR)

^{*}Note - Shock levels increased to 30G.

Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

Please note: This report is intended to cover families MSLB-2-XXXX-1-X-XXXXXX and MSLB-2-XXXXX-2-X-XXXXXX.

Model Nomenclature (Example: MSLB-2-0606-2-S-AAAA00)

		MS	SLB-2- <u>XXXX-X-X-X</u> -X		ightharpoons
Product	Gener	Nominal	Number of	Input Voltage	System Color
Family	ation	System Wattage	Modules		
		(x100)			
MSLB	2	01=100W	01=1 module	1=100-277VAC,50/60Hz	W=White
		02=200W	02=2modules		S=Standard
		03=300W	03=3modules	2=347VAC,50/60Hz	B=Black
		04=400W	04=4modules		
		05=500W	05=5modules		
		06=600W	06=6modules		

	MSLB-2-XXX	X-X-X- <u>XXXX</u>	<u>XX</u>		
↓		₩	—	$\overline{}$	\downarrow
1 st X	2 nd X	3 rd X	4 th X	5 th X	6 th X
A=5000CCT,70CRI,C	A=3mm Glass, Clear, no	A=0-10V	A=Indoor Electrical	TB	TBD
9000 Array	reflector	dimming	box	D	
B=4100CCT,70CRI,C	B=Dome, Clear, no reflector				
9000 Array	C=3mm Glass, Diffuse, no	B=Static	C=Pigtails		
C=5600CCT,70CRI,C	reflector				
9000 Array	D=Dome, Diffuse, no reflector	C=PWM	D=5/8"BX		
D=3000CCT,80CRI,C	E=Dome, Clear, Type 3 Med	D DALL	E 0 Day and 1		
9000 Array	reflector	D=DALI	E=3 Prong plug		
E=2700CCT,80CRI,C 9000 Array	F=Dome, Diffuse, Type 3 Med reflector	E=DMX			
F=5000CCT,70CRI,C	G=Dome, Clear, Type 4 Med	E=DIVIX			
5000 Array	reflector				
G=4100CCT,70CRI,C	H=Dome, Diffuse, Type 4				
5000 Array	Med reflector				
H=5600CCT,70CRI,C	I=6mm Glass, Clear, no				
5000 Array	reflector				
I=3000CCT,80CRI,C	J=6mm Glass, Diffuse, no				
5000 Array	reflector				
J=2700CCT,80CRI,C					
5000 Array					

Additionally the product may be configured as consisting of anywhere between 1 to 6 LED modules.

For example: MSLB-2-0606-1-S-AAAA00 is 6 module, 600W, 120/277VAC, Standard Color (Aluminum color), C9000 Array (CCT5000,CRI70), 3mm clear flat glass (no reflector), dimming indoor electrical box.



Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

Table 1.3 is a detailed summary of the effects of test conditions as prescribed by the aforementioned test document on the functionality of the camera and charger.

1.2 Revision History

Revision Number	Description	Revision performed by
1.0	None, original	N/A

1.3 Test Result Summary

The table below summarizes the test results of luminaire models MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00. The details of tests are located in the appropriate Annex for the section under investigation.

Note: The information in the table below should not be used without understanding the underlying circumstances of the test results that are presented in the Annexes of this report.

TABLE 1.3: TEST RESULTS SUMMARY

Criteria	Sample	Results	Annex	Comment
Earthquake	MSLB-2-0606-1-B-AAAA00	Pass	2	Vertical Axis Only
	MSLB-2-0606-2-B-AAAA00			
Equipment Anchor	MSLB-2-0606-1-B-AAAA00	Pass	3	
Criteria	MSLB-2-0606-2-B-AAAA00			
Shocks	MSLB-2-0606-1-B-AAAA00	Pass	4	Vertical Axis Only
	MSLB-2-0606-2-B-AAAA00			•

Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

2.0 ANALYSIS SCOPE

2.1 Product Description

2.2 Modifications Necessary for Compliance

The following modifications were incorporated into the EUT in order to fully comply with the requirements of the specification: None.

2.3 EUT Operability

The units were tested in a non-operating state without packaging, as they would normally be installed. Proper operation was verified at the conclusion of testing.

2.4 Testing Facilities

Test Category	Location
Earthquake	UL; RTP, NC
Equipment Anchor Criteria	UL; RTP, NC
Shocks	UL; RTP, NC

Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

3.0 UL Technical Staff

The following personnel supervised and/or performed technical aspects of the test program:

Michelle Henderson (919) 549-1471

WiSE Operations Manager

Chris Rose (919) 549-1713

WiSE Engineer

4.0 Analysis Criteria

The criteria against which the meters were analyzed are contained in the following documents:

- Telcordia Technologies GR-63-CORE, Issue 4, April 2012
- ETSI EN 300019-2-3 V2.2.2 (2003-2004)

Model Number: MSLB-2-XXXX-1-X-XXXXXX and MSLB-2-XXXX-2-X-XXXXXX

ANNEX 1 – Equipment Photos

Figure A1- 1: MSLB-2-0606-1-B-AAAA00 (Top)



Figure A1- 2: MSLB-2-0606-1-B-AAAA00 (Bottom)



Issued: October 31, 2012 Revision: 1.0 Client Name: Bridgelux Pridgelux Pridgelux Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00 Project Number: 12CA49116

Figure A1- 3: MSLB-2-0606-2-B-AAAA00 (Top)



Figure A1- 4: MSLB-2-0606-2-B-AAAA00 (Bottom)



Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

ANNEX 2 – Earthquake

Criteria

Coordinate Point	Frequency [Hz]	Values for upper floor acceleration [m/s²]
1	1	30
2	2	50
3	5	50
4	15	15
5	35	15

Method

Subject the equipment to the VERTEQII waveform. Verify the TRS meets or exceeds the RRS in the frequency range from 1.0 to 50 Hz. If the TRS is below the RRS at any point, use the last drive signal and table acceleration to update the transfer function. Apply it to the Telcordia waveform to generate a new drive signal, and retest the equipment. Repeat this step as necessary. The TRS should not exceed the RRS by more than 30% in the frequency range of 1 to 7 Hz. A test may be invalid if an equipment failure occurs when the TRS exceeds the RRS by more than 30% in this frequency range.

Results


SAMPLE	AXIS	RESULT	COMMENTS
MSLB-2-0606-1-B-AAAA00	Vertical	Pass	
MSLB-2-0606-2-B-AAAA00	Vertical	Pass	


]The	equi	pment	<u>did</u>	sustain	phy	sical	and/or	function	nal dama	ge.	
X	1The	eaui	pment	did	not sus	stain	anv	physica	I and/or	function	al dan	nage.

Test Instruments


Description	Serial Number	Manufacturer	Model	Cal. Date	Cal. Due
Signal Conditioner	AX0037	LDS	Laser	2011/12/30	2012/12/30
Accelerometer	AX0023	PCB	J353B15	2012/02/20	2013/02/28
Accelerometer	AX0030	Dytran	3202A1	2011/12/16	2012/12/31














Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

Annex 3: Equipment Anchor Criteria

Criteria

The fastening systems used for the EUT shall withstand a force of 3 times the weight of the EUT applied to the equipment in the vertical direction.

Procedure

- 1. Measure and document the weight of the equipment.
- 2. Mount the equipment using the fastening system provided/specified by the manufacturer per the installation documentation.
- 3. Apply a force of 3 times the measured weight to the equipment in the vertical direction.

Results

Model	Weight of EUT (lbs)	Applied Force (3 * Weight of EUT)	Results of Applied Force (Pass/Fail)
MSLB-2-0606-2-B-AAAA00	60	180lbs	Pass
MSLB-2-0606-1-B-AAAA00	57	180lbs	Pass

Test Instruments


Description	Serial Number	Manufacturer	Model	Cal. Date	Cal. Due
Scale	WD0086	Mettler Toledo	VLF01023	2012/03/28	2013/03/28



14

Issued: October 31, 2012 Revision: 1.0 Project Number: 12CA49116

Client Name: Bridgelux Pridgelux Pridgelux Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00





Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00

Annex 4: MECHANICAL SHOCK

Criteria

Shock Spectrum	Duration (ms)	Acceleration (m/s ²)	Number of Shocks/Direction		
Half sine	11ms	300 (30g)	1		

Test Method

- 1. The equipment under test shall be mounted to the vibration table.
- 2. Measure the input acceleration with a suitable transducer.
- 3. Subject the equipment to the shock spectrum listed above.
- 4. The sample is configured in its in-use orientation.
- 5. Testing is conducted in the vertical axis only.

Results


Model	Axis	Results of Applied Force (Pass/Fail)
MSLB-2-0606-2-B-AAAA00	Vertical	Pass
MSLB-2-0606-1-B-AAAA00	Vertical	Pass

The	equipme	ent	<u>did</u>	sustain	ı physica	ıl an	d/or	fu	nctio	nal	dama	age.	
<u> </u>										•			

Test Instruments


Description	Serial Number	Manufacturer	Model	Cal. Date	Cal. Due
Signal Conditioner	VE0008	UD	CVA-8	2012/12/15	2013/12/31
Signal Generator	PC0021	UD	DSP-8	2012/03/26	2013/03/31
Signal Generator	PC0022	UD	DSP-2	2012/03/26	2013/03/31
Signal Generator	PC0023	UD	VGN-8	2012/03/26	2013/03/31
Accelerometer	AX0012	PCB	J353B31	2011/05/17	2013/05/31


The equipment <u>did not</u> sustain any physical and/or functional damage.





Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00





0.0

-10.0

-20.0

-30.0

292 298.8

242

Issued: October 31, 2012 Revision: 1.0 Client Name: Bridgelux Pridgelux Pridgelux Model Number: MSLB-2-0606-1-B-AAAA00 and MSLB-2-0606-2-B-AAAA00 Project Number: 12CA49116



